

# Danish Indoor Climate Labelling Certificate no. 007



*Danish Indoor Climate Labelling hereby certifies that the product group*

**Danoline Products (Perforated and Unperforated Prepainted or Laminated Surfaces) including Suspension System**

*manufactured by*

**Danogips A/S  
Antoinettevej 3  
DK-2500 Valby**

*has been approved and awarded a labelling licence*

*The declared indoor-relevant time-value has been determined according to the labelling criteria listed in the following documents issued by the Danish Society of Indoor Climate:*

*Testing and Labelling Criteria for  
Wall and ceiling systems, 3<sup>rd</sup> edition, 2005  
and General Labelling Criteria, 4<sup>th</sup> edition, 2005.*

*The certificate is based on tests of Contur 600, Plaza 600 and Tectopanel*

*The certificate is valid 5 years from:*

**1<sup>st</sup> May 2006**

*and is subject to annual renewal by attestation of the Schedule 1-007 to this certificate according to the procedures of Danish Indoor Climate Labelling.*

*Danish Indoor Climate Labelling may withdraw the rights to use this Certificate in case the company does not meet the requirements.*

*This certificate including Schedule 1-007 can also be found at:  
[www.teknologisk.dk/DIM](http://www.teknologisk.dk/DIM)*

**For Danish Indoor Climate Labelling**

*Thomas Wittend*  
Certification Manager



**30.08.2006**

Date

# Danish Indoor Climate Labelling

## Certificate no. 007



### Schedule 1-007

**Certificate Holder:**

Danogips A/S  
Antoinettevej 3  
DK-2500 Valby

Particle emission including fibres is classified in three classes

| Category | Limits (mg/m <sup>2</sup> ) | Accept |
|----------|-----------------------------|--------|
| Low      | $X \leq 0.75$               | Yes    |
| Medium   | $0.75 < X \leq 2$           | Yes    |
| High     | $2 < X$                     | No     |

The certificate was first issued on:  
1<sup>st</sup> May 1995

**Labelling Licence Basis:**

*Danish Indoor Climate Labelling*: Testing and Labelling Criteria for Wall and ceiling systems, 3<sup>rd</sup> edition, 2005. The maximum acceptable time-value for ceiling systems is determined as 60 days. The certificate applies to products considered to be identical with the tested product regarding indoor climate characteristics as specified by the labelling criteria.

Particle emission is determined by sedimentary dust of particles including fibres, which might cause irritation of the skin or the eyes, nose and upper airways in the initial period of use of the product. Products under this certificate are classified as **low**.

**Product Characteristics:**

The certificate and the declared indoor-relevant time-value comprise exclusively the product group characteristics in relation to odour and irritation of the eyes, nose and upper airways. The declared indoor-relevant time-value is determined on basis of the results of chemical analyses as well as sensory evaluations. Declared time-value:

**20 days**

**Product information Requirements:**

The holder of the certificate is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor climate in practice: product specifications, a list of trade names covered by the certificate, guidelines for projecting, transport, storage, assembly, limitation of applications, cleaning and maintenance.

**Monitoring and Renewal of Labelling Licence:**

*Danish Indoor Climate Labelling* monitors and exercises control in accordance with its procedures in force at any time. The certificate is valid only in combination with the present schedule stating the dates of first issue, renewal and expiration, and signed by the Certification Manager of *Danish Indoor Climate Labelling*.

The application for renewal of the labelling licence filed by the certificate holder has been considered according to the requirements of the *Danish Indoor Climate Labelling* with a satisfactory result:

|                                   |  |  |  |  |
|-----------------------------------|--|--|--|--|
| Labelling licence Date of renewal |  |  |  |  |
| Attestation of latest renewal     |  |  |  |  |
| Labelling licence Date of expiry  |  |  |  |  |

**In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.**